

I/161208/2021



West Bengal State Agricultural Marketing Board

“Kamal Guha Krishi Bipanan Bhawan”,

729, Anandapur, P.O. E.K.T.P., P.S. Anandapur, Kolkata – 700 107

Mail Id:- wbstatemarketing@yahoo.co.in

NOTICE INVITING QUOTATION

Memo No. 3155 /WBSAMB-15015/16/2021-SEC-WBSAMB

Dated : 26/11 /2021

N.I.Q. No. WBSAMB/35/2021-22

Dated : 24/11/2021

Sealed Quotations are hereby invited from the reputed and reliable firms for following work. The last date of submission of Quotation is **14:00 Hrs of 08.12.2021**, which will be accompanied by self attested Trade License, PAN Card, GST, Electrical Supervisor's Certificate of competency (1, 2, 4, 5, 6A, 7A, 7B,11). The Quotation will be opened at **15:00 Hrs on the same day** in presence of quotationers or their authorized representatives. The quotationers should follow the terms and conditions as given below:-

Name of Work: Supply and erection of electrical equipments (at site) for internal electrification work in connection with proposed Food Testing Labotary Principal Market Yard of Siliguri RMC. District Darjeeling..

Terms & Conditions

1. The Chief Executive Officer, West Bengal State Agricultural Marketing Board reserves the right to accept or reject any bid without assigning any reason thereof and to cancel the tender at any stage.
2. The Rate to be quoted including of all taxes and charges and delivery at sites.
3. The quotationers should quote their rates in prescribed format attached with this notice.
4. In case of failure of compliance of the terms and conditions Supply Order, the contract will be terminated along with forfeiture of earnest money.
5. Time period of contract of work is 15 (Fifteen) days.
6. Statutory deduction will be made from each bill as per norms.
7. The prescribed format of quotation should submit in a separate sealed envelope.

Chief Executive Officer

West Bengal State Agricultural Marketing Board


Item Wise BOQ

Name of Work: SUPPLY AND ERECTION OF ELECTRICAL EQUIPMENTS (AT SITE) FOR INTERNAL ELECTRIFICATION WORK IN CONNECTION WITH PROPOSED FOOD TESTING LABOTARY PRINCIPAL MARKET YEARD OF SILIGURI RMC. DISTRICT DARJEELING.

NIQ NO :

SL No	Description of Item	Qty	Unit	Rate (Incl Tax)	Amount
1	Supplying and Drawing 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required.				
2	4x80/0.4 (10 sqmm) + 2x84/0.3 (6 sqmm) as ECC	70.00	RM		
3	Distribution wiring in 1.1 KV single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in 25mm size PVC rigid conduit 'FR' (Precision make) incl. necy. fittings as required				
4	4 x 84/0.3 (6 sqmm) + 2 x 56/0.3 (4 sqmm) ECC from HTPN DB to IP	120.00	RM		
5	Fixing of 415V, TPN SFU with sheet steel enclosure on flat iron/angle iron frame on wall with nuts bolts etc incl. S & F 3 nos. DIN type HRC fuse as per rating.				
6	250AMP	1.00	Each		
7	Fixing of Industrial Plug & Socket board with 415 V, 30A, TPN & Earth Metal Industrial Plug socket & 30A Industrial top incl. S&F 32 A TPN/FP MCB breaking capacity 10kA (C- Curve) in SS enclosure fixed on wall and necessary conection	14.00	Each		
8	Fixing of double door Vertical TPN MCB Distribution board for MCCB incomer with IP-42/43 protection, on angle iron frame on wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment Up to 160A Up to 160A				
9	6 way Enclosure (LTVD06MGN)	1.00	Each		
10	Fixing of double door Horizontal TPN MCB Distribution board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment				
11	6 way Enclosure (LTTD06N)	4.00	Each		
12	Supplying and fixingFixing of with fixed thermal and fixed magnetic / adjustable thermal and fixed magnetic setting in existing DBs / enclosure and necessary connection				
13	100 A	6.00	Each		
14	250 A	1.00	Each		
15	Fixing of 415 V 63 AMP FP MCB of Breaking capacity 10kA & C characteristics on din rail of existing DBs and necessary connection	24.00	Each		
16	Connecting the equipments to early busbar incl. S&F No. 8 SWG G.I. wire on wall /floor with stapels as per G.S.	200.00	Mtr		
17	Supplying and fixing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture-proof entry of XLPE/PVC armoured cables as below				
18	For 3½ core				
19	upto 50 sqmm	2.00	Each		
20	Finishing the end of following XLPE/PVC armoured cables by crimping method incl. supplying and fixing solderless socket (Dowels make), tapes, anticorrosive paste & jointing materials				
21	3½ core 50 sqmm cable	12.00	Set		
22	Laying of cable above 3½ core 50 sqmm and upto 3½ core 90 sqmm on wall/surface including S & F MS clams with earthing attachment in 2 x 10 SWG GI (Hot Dip) Wire, making hole etc. as necy., mending good damages and painting	50.00			
22	Total Amount				

Amount in Wards:


 Chief Executive Officer
 West Bengal State Agricultural
 Marketing Board